

## UQGS.S36306 - Heat-automatic Fire Detectors

## Heat-automatic Fire Detectors

See General Information for Heat-automatic Fire Detectors

**MTECH FIRE DETECTION SYSTEMS LTD**

KIBBUTZ HASOLELIM  
17905 D.N HAMOVIL, ISRAEL

S36306

Model No.	Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft)	
					Smooth Ceiling	to Wall or Partition
<b>MA-330(**)</b>	FT/ROR	D2	-	135, 194	50	25
<b>MA-340</b>	FT	D2	-	135	50	25
<b>MB-230</b>	FT	D2	-	135	50	25
<b>MB-240</b>	FT	D2	-	135	50	25

Base Model	Related Detector	Control Unit Compatibility Restrictions
<b>MA-300</b>	MA-320, MA-340	B2
<b>MB-300</b>	MB-220, MB-240	B2

B2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

FT/ROR - Fixed temperature/rate of rise combination

FT - Fixed temperature

(\*\*) - Temperature rating is programmable at the Listed compatible control unit

Note - Detectors MB-230, MB-240 is Compatible with Detector Base MB-300 and Detectors MA-330, MA-340 is Compatible with Base MA-300

Last Updated on 2020-06-18

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"